

TAMIL NADU FIRE AND RESCUE DEPARTMENT

FIRE AND RESCUE STATION - SURAMANGALAM.

Roc: No: 4/2023

Date : 11.05.2023

NO OBJECTION CERTIFICATE

Sub: Fire Station-Suramangalam-School /Establishment Of School-For Approval
-No Objection Certificate -Regarding.

Ref: 1. Govt.Go.No.122 School Education (2) Dept. Dt :14.09.2004
2. Govt.Go.No.123 School Education (2) Dept. Dt :14.09.2004
3. Govt.Go.No.177 School Education (2) Dept. Dt :07.09.2004
4. The Application From Principal **SRK GLOBAL SCHOOL (CBSE)**,
Membala Nagar, Kandhampatty East, Salem-636 005.

Application Date : 08.05.2023.

As per above stated government order and the application, The school named **SRK GLOBAL SCHOOL (CBSE)**, at the address Membala Nagar, Kandhampatty East, Salem-636 005. was **INSPECTED** by the **STATION OFFICER SURAMANGALAM Mr.F.SIRAJ AL VANISH** on 11.05.2023. In this view of the Fire And Rescue Service Department has **NO OBJECTION** to issue the recognition of the school.

(This certificate valid upto one year from the date of issue)

CONDITIONS

1. Fire and first aid equipment must be properly maintained.
2. ABC (DCP) 4kg/6kg to be installed at stationery store such as notebooks, files and clothes.
3. CO₂ 2 kg/4kg to be installed in areas of electrical & electronical fittings.
4. First Aid Box should be kept at sports room.
5. Mock drill during fire emergency to be conducted.
6. LPG cylinder to be installed and maintained as per the norms.



Handwritten signature and date: 11/5/23
நிலைய அலுவலர்.
தீயணைப்பு-மீட்பு பணிகள் நிலையம்.
சுரமங்கலம் சேலம்-5

To

The Principal,
SRK GLOBAL SCHOOL (CBSE),
Membala Nagar, Kandhampatty East,
Salem-636 005.

Copy To

1. The Join Director, West Region Coimbatore-18.
2. The District Officer, Salem District-636 007.